

Cleanroom, data hall and lab cleaning: what we clean

Walk the controlled spaces and check each line against your own procedure.

Facility _____ Address _____

Walked by _____ Date _____

Entry and gowning

- ☐ Your gowning order followed at the anteroom
- ☐ Tacky mats and air showers used as directed
- ☐ Carts, handles and buckets wiped before entry
- ☐ Room-assigned tools kept in that room
- ☐ Sign-in log or cleaning record kept if required

Cleanrooms

- ☐ Ceiling grid and filter-unit frames first
- ☐ Walls and pass-throughs worked downward
- ☐ Work surfaces before the floor
- ☐ Cleanest zone toward the exit, no backtracking
- ☐ Low-lint wipes, cleanroom mops and your approved agents

Data halls

- ☐ Visits booked ahead, badged or escorted
- ☐ Only cages, rows and rooms in the access plan
- ☐ Racks, cabling and equipment never touched
- ☐ Floor tiles lifted in sequence with approval
- ☐ Under-floor space vacuumed with filtered equipment
- ☐ Perforated tiles and floor around cooling units

Support rooms

- ☐ Loading docks and staging areas
- ☐ Battery and electrical rooms where approved
- ☐ Network operations center
- ☐ Offices and break rooms

Labs and R&D

- ☐ Lab floors, sinks and door hardware
- ☐ Shared surfaces on your schedule
- ☐ Benches, instruments and chemical storage left to your staff
- ☐ No-entry rooms marked on the floor plan
- ☐ Lab waste streams left to lab staff
- ☐ Restrooms and break rooms on janitorial service

Scheduling

- ☐ Shift changes, maintenance windows or shutdowns
- ☐ Overnight or weekend visits
- ☐ Plan updated when a room or procedure changes

Notes
